

ORDINANCE

AN ORDINANCE OF THE COUNCIL OF
23
THE CITY OF COOKEVILLE,
TENNESSEE, AMENDING TITLE 18,
CHAPTER 2, OF THE COOKEVILLE
MUNICIPAL CODE, PERTAINING TO
SEWER USE ORDINANCE

ORDINANCE NUMBER: 007-08-

REQUESTED BY: RONNIE KELLY
PREPARED BY: CAREY VAUGHN
APPROVED AS TO
FORM/CORRECTNESS:

(City Attorney)
PASSED FIRST READING: _____
PASSED 2ND READING: _____
MINUTE BOOK _____ PAGE _____

THE BOARD OF MAYOR AND CITY COUNCIL OF THE CITY OF
COOKEVILLE, TENNESSEE HEREBY ORDAINS:

SECTION I. That Title 18, Chapter 2 of the Cookeville Municipal Code be
amended as follows:

CHAPTER 2 - SEWER USE ORDINANCE

SECTION
18-204. General Regulations

18-204. General Regulations.

(3) Restricted Discharges.

(a) No person or user shall discharge wastewater which
exceeds the following concentrations unless an exception is permitted as
provided in this chapter. Dilution of any wastewater discharge for the purpose
of satisfying these requirements shall be considered a violation of this chapter.

<u>Parameter</u>	<u>Monthly Average* Concentration (mg/L)</u>
Copper	5.0
Chromium	5.4
Nickel	4.7
Cadmium	0.18
Lead	1.87
Mercury	0.0007
Silver	1.16
Zinc	5.0
Cyanide	0.34
Toluene	4.19

*Based upon composite or grab samples as required by 40 CFR 136.

<u>Parameter</u>	<u>Monthly Average* Concentration (mg/L)</u>
Benzene	0.28
1,1,1-Trichlorethane	3.98
Ethylbenzene	0.55
Carbon Tetrachloride	1.98
Chloroform	5.11
Tetrachloroethylene	2.5
Trichloroethylene	1.8
1,2 Transdichloroethylene	0.21
Methylene Chloride	2.63
Phenols, Total	5.0
Naphthalene	0.21
Total Phthalates	6.0

Total Phthalates is the sum of Bis (2-ethylhexyl) phthalate, Butyl Benzylphthalate, Di-N-butylphthalate, and Diethylphthalate.

*Based on composite or grab samples as required in 40 CFR 136.

(b) No person or user shall discharge any waters or wastes which cause the wastewater leaving the treatment facility to exceed any of the maximum concentration limits for a 24-hour composite sample shown below. This may require a reduction of values set out for individual discharges.

<u>Parameter</u>	<u>Pass Through Concentration (µg/L)</u>
Copper	40.01
Chromium	60.00
Nickel	180.00
Cadmium	1.21
Lead	23.59
Mercury	0.05
Silver	5.00
Zinc	200.00
Cyanide	4.81
Toluene	15.00
Benzene	3.00
1,1,1-Trichloroethane	30.00
Ethylbenzene	4.00
Carbon Tetrachloride	15.00
Chloroform	85.00
Tetrachloroethylene	25.00
Trichloroethylene	10.00
1,2 Transdichloroethylene	1.50
Methylene Chloride	50.00
Phenols, Total	50.00
Naphthalene	1.00
Total Phthalates	64.50

Total Phthalates is the sum of Bis (2-ethylhexyl) phthalate, Butyl Benzylphthalate, Di-N-butylphthalate, and Diethylphthalate.

SECTION II. That this ordinance shall take effect fourteen (14) days from and after its final passage.

MAYOR